



## TOWNSHIP OF EDWARDSBURGH CARDINAL INFORMATION ITEM

**Committee:** Administration & Operations

**Date:** May 12, 2025

**Department:** Parks / Recreation & Facilities

**Topic:** 1st Quarter 2025 Facility Maintenance Report

**Background:** Below you find a list of work performed at Township facilities during the 1<sup>st</sup> quarter of 2025. These work orders are above the daily routines at our facilities.

### **Ingredion Centre:**

- (WO-5004) NO power to HVAC system – repaired with new interface board
- (WO-5109) brine leak repair in compressor room
- (WO-5113) Replaced 4 exterior lights in parking lot – ESA updated
- (WO-5113) replaced the boiler system for in-floor heating
- (WO-5123) tested & tagged all safety valves in compressor room
- (WO-5165) replaced Zamboni hot water tank
- (WO-5235) repaired gas valve on dehumidifier
- (WO-5278) plant shut down by Cimco for both rinks

### **Spencerville Arena:**

- (WO-5147) replaced safety valves in compressor room per Cimco recommendation
- (WO-3543) Electrical Safety Inspection

### **Town Hall**

- (WO-4994) installed mother board for the boiler system
- (WO-5206) replaced parts on water pump for furnace

A handwritten signature in black ink, appearing to be 'JS' or similar, written over a horizontal line.

Facilities Manager