

Committee: Administration & Operations

Date: April 13, 2026

Department: Parks / Recreation & Facilities

Topic: 1st Quarter 2026 Facility Maintenance Report

Background: Below you find a list of work performed at Township facilities during the 1st quarter of 2026. These work orders are above the daily routines at our facilities.

Ingredion Centre:

- (WO-6169) fire security panel inspection & tagging tested
- (WO-6315) Power outage, plant would not restart, Cimco called in
- (WO-6443) HVAC unit fuse replacement

Spencerville Arena:

- (WO-6151) Fire panel and smoke detector testing
- (WO-6167) Mid-season inspection on compressor room
- (WO-6168) leak detector test and calibrated
- (WO-6177) Surprised TSSA inspection on compressor room
- (WO-6241) Cimco into check on dehumidifier
- (WO-6444) Lift Gate service call, counterweights repaired

Town Hall

- (WO-6201) Abell best control inspection
- (WO-6345) Lift Inspection
- (WO-6113) replaced all smoke detectors



Facilities Manager