



TOWNSHIP OF EDWARDSBURGH CARDINAL INFORMATION ITEM

Committee: Public Works, Environmental Services & Facilities

Date: Tuesday February 18th, 2020

Department: Facilities

Topic: 4th Quarter Facility Maintenance Report Update

Background:

Below you will find a list of work performed at Township facilities during fourth quarter of 2019.

South Centre

- New slide for the play structure is in and will be installed in the spring
- Picnic tables and garbage cans put away for the winter
- Abell Pest Control was in for their monthly inspections - no issues to report

Ingredion Centre

- Carbon Monoxide sensors were tested in November – no issues to report
- Fire alarm system tested in October by Falcon Security – no issues to report
- December – Mid season inspection by Cimco refrigeration – one relief valve replaced
- Electrical Safety Authority inspections – no issues to report

Spencerville Arena

- Zamboni issues – parts were ordered – we were able to use Prescott's machine during the 6 days while waiting for parts.
- Fire alarm tested in November by Falcon Security – no issues to report
- Electrical Safety Authority inspections – no issues to report